

1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

W-11

Lab ID No. 02-04041

Lab# 416

5/30/25

Sample Final Analysis

Date:

Customer Sample Collection

Facility Name: Drury Hotel Date: 5/27/25 Time: 9:15 AM Grab

Address: 101 Ridge Rd. Method: Pittsburgh, PA 15205

Matrix: Recreational Water

Time: 9:00 AM

Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	5/27/25	2:55 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/28/25	11:30 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	5/27/25	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	9:15 AM	VH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

W-11

Lab ID No. 02-04041

Lab# 416

5/30/25

Sample Final Analysis

Date:

Customer Sample Collection

Facility Name: Drury Hotel Date: 5/27/25 Time: 9:15 AM Grab

Address: 101 Ridge Rd. Method: Pittsburgh, PA 15205

Matrix: Recreational Water

Time: 9:00 AM

Source Type: Spa Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	9:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	9:15 AM	EB	SM 9222B
Standard plate count:	120/ml	200/ml	5/27/25	2:55 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/28/25	11:30 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.6 SU	7.2 - 7.8 SU	5/27/25	9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/27/25	9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	9:15 AM	VH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor