



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2453

Customer

Facility Name: *Rosedale Beach*
Address: *5407 3rd St.*
Verona, PA 15147

Sample Collection

Date: *6/16/25*
Time: *9:48 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/19/25*
Time: *10:00 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 | 9:20 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/17/25 | 9:20 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/16/25 | 2:46 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 6/16/25 | 9:48 AM | EH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 9:48 AM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 9:48 AM | EH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2453

Customer

Facility Name: *Rosedale Beach*
Address: *5407 3rd St.*
Verona, PA 15147

Sample Collection

Date: *6/16/25*
Time: *9:48 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/19/25*
Time: *10:00 AM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 6/17/25 | 9:20 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 6/17/25 | 9:20 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/16/25 | 2:46 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 6/16/25 | 9:48 AM | EH | DPD |
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 6/16/25 | 9:48 AM | EH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/16/25 | 9:48 AM | EH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor