



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 472

Customer

Facility Name: Hollidaysburg HS
Address: 1510 North Montgomery St.
Hollidaysburg, PA 16648

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/22/25
Time: 1:00 PM
Method: Grab

Sample Final Analysis

Date: 9/25/25
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/23/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/23/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/22/25	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	9/22/25	1:00 PM	DNP	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/22/25	1:00 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/25	1:00 PM	DNP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor