



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 028

Customer

Facility Name: *Burrell High School*
Address: *1021 Puckety Church Rd.*
Lower Burrell, PA 15068

Sample Collection

Date: *9/4/25*
Time: *11:52 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *9/6/25*
Time: *2:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/4/25	4:30 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/4/25	4:30 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	9/4/25	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/4/25	11:52 AM	SL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	9/4/25	11:52 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/4/25	11:52 AM	SL	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor