

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2436

AS

CustomerFacility Name:Trellis North FayetteDate:7/15/25Time:11:04 AMAddress:1500 Park Lane Drive
Pittsburgh, PA 15275Method:GrabSample Final Analysis

Matrix: Recreational Water Date: 7/18/25
Time: 9:30 AM

Source Type: Spa Analyst:

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	10:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25	4:20 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/16/25	11:50 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/15/25	11:04 AM	АН	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/15/25	11:04 AM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	11:04 AM	AH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-13

Lab# 2436

AS

CustomerFacility Name:Trellis North FayetteDate:7/15/25Time:11:04 AMAddress:1500 Park Lane Drive
Pittsburgh, PA 15275Method:GrabSample Final Analysis

Matrix: Recreational Water Date: 7/18/25
Time: 9:30 AM

Source Type: Spa Analyst:

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	10:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25	4:20 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/16/25	11:50 AM	АН	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	7/15/25	11:04 AM	АН	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/15/25	11:04 AM	АН	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	11:04 AM	AH	Visual

Sample comments

andre Smith

(When exceeding reporting limit pool or spa is unfit)