Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# **2257**

Customer

			Sample Collection	
Facility Name:	Highland Park Club		Date:	6/2/25
			Time:	2:00 PM
Address:	1001 N. Negley Ave.		Method:	Grab
	Pittsburgh, PA 15206			
			Sample Final Analysis	
Matrix:	Recreational Water		Date:	6/5/25
			Time:	9:30 AM
Source Type:	Pool		Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/2/25	2:00 PM	LM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	2:00 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	2:00 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# *2257*

Customer

Facility Name:	*Highland Park Club*
Address:	*1001 N. Negley Ave.*
	Pittsburgh, PA 15206
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/2/25*
Time:	2:00 PM
Method:	*Grab*

Sample Final Analysis

Date:	*6/5/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	9:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/2/25	2:00 PM	LM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/2/25	2:00 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	2:00 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor