



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2373

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Nob Hill*
Address: *3000 Swallow Hill Rd.*
Pittsburgh, PA 15220

Date: *5/27/25*
Time: *2:27 PM*
Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Pool*

Date: *5/30/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/27/25	2:27 PM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/27/25	2:27 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25	2:27 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2373

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Nob Hill*
Address: *3000 Swallow Hill Rd.*
Pittsburgh, PA 15220

Date: *5/27/25*
Time: *2:27 PM*
Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*
Source Type: *Pool*

Date: *5/30/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25 11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25 11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	5/27/25 7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/27/25 2:27 PM	CW	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/27/25 2:27 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25 2:27 PM	CW	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor