



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 464

**Customer**

Facility Name: *Big Blue Swim School*

Address: *20412 US Rt19  
Cranberry, PA 16066*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *7/7/25*

Time: *1:01 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/10/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:58 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/7/25	1:01 PM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:01 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:01 PM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

*Andre Smith*



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 464

**Customer**

Facility Name: *Big Blue Swim School*

Address: *20412 US Rt19  
Cranberry, PA 16066*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *7/7/25*

Time: *1:01 PM*

Method: *Grab*

**Sample Final Analysis**

Date: *7/10/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	7/8/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/8/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/7/25	3:58 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	7/7/25	1:01 PM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/7/25	1:01 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/7/25	1:01 PM	ZR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

*Andre Smith*