



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 383**

**Customer**

Facility Name: Hilton Garden Inn  
Address: 9600 University Blvd  
Pittsburgh, PA 15108

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 6/2/25  
Time: 8:50 AM  
Method: Grab

**Sample Final Analysis**

Date: 6/5/25  
Time: 9:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	6:45 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/3/25	11:30 AM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	6/2/25	8:50 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	8:50 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	8:50 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 383**

**Customer**

Facility Name: Hilton Garden Inn  
Address: 9600 University Blvd  
Pittsburgh, PA 15108

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 6/2/25  
Time: 8:50 AM  
Method: Grab

**Sample Final Analysis**

Date: 6/5/25  
Time: 9:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/2/25	6:45 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/3/25	11:30 AM	AH	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	6/2/25	8:50 AM	AH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/25	8:50 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/25	8:50 AM	AH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor