



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2602

Customer

Facility Name:

Woodridge Condos

Address:

100 Woodridge Circle
Pittsburgh, PA 15234

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date: 7/15/25

Time: 8:28 AM

Method: Grab

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25	3:01 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/15/25	8:28 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/15/25	8:28 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	8:28 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2602

Customer

Facility Name:

Woodridge Condos

Address:

100 Woodridge Circle
Pittsburgh, PA 15234

Matrix:

Recreational Water

Source Type:

Pool

Sample Collection

Date: 7/15/25

Time: 8:28 AM

Method: Grab

Sample Final Analysis

Date: 7/17/25

Time: 8:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/16/25	9:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/15/25	3:01 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/15/25	8:28 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/15/25	8:28 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	8:28 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor