



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2723**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Traditions of America Southpointe*  
*Address: 105 Liberty Blvd.*  
*Cannonsburg, PA 15317*

*Date: 7/30/25*  
*Time: 12:10 PM*  
*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*  
*Source Type: Pool*

*Date: 8/1/25*  
*Time: 3:30 PM*  
*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	5:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	5:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/30/25	12:10 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/30/25	12:10 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	12:10 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2723**

**Customer**

*American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Sample Collection**

*Facility Name: Traditions of America Southpointe*  
*Address: 105 Liberty Blvd.*  
*Cannonsburg, PA 15317*

*Date: 7/30/25*  
*Time: 12:10 PM*  
*Method: Grab*

**Sample Final Analysis**

*Matrix: Recreational Water*  
*Source Type: Pool*

*Date: 8/1/25*  
*Time: 3:30 PM*  
*Analyst: AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	5:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	5:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	7/30/25	12:10 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/30/25	12:10 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	12:10 PM	AF	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor