



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2757

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Here Apts*

Date: *8/18/25*

Address: *3506 Forbes Ave*
Pittsburgh, PA 15213

Time: *11:20 AM*

Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Date: *8/21/25*

Source Type: *Spa*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	8/19/25 9:00 AM	EB	SM 9222G
-------------------	--------	--------	----------------------	----	----------

Total coliforms:	0/100mls	2/100mls	8/19/25 9:00 AM	EB	SM 9222B
------------------	----------	----------	----------------------	----	----------

Standard plate count:	0/ml	200/ml	8/18/25 2:42 PM	SL	SM 9215B
-----------------------	------	--------	----------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	8/19/25 11:00 AM	EB	SM 9230C
---------------------	----------	----------	-----------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	8.0 SU	7.2 - 7.8 SU	8/18/25 11:20 AM	LM	DPD
-----	--------	--------------	-----------------------	----	-----

Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/18/25 11:20 AM	LM	DPD
-----------	----------	----------------	-----------------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	8/18/25 11:20 AM	LM	Visual
------------	-------	-----------	-----------------------	----	--------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor