



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 388

Customer

Facility Name: Towne Place Suites
Address: 2020 Cool Springs Dr.
Cranberry Township, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/9/25
Time: 1:24 PM
Method: Grab

Sample Final Analysis

Date: 7/12/25
Time: 8:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/10/25	10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25	10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/9/25	1:24 PM	ZR	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/9/25	1:24 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	1:24 PM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 388

Customer

Facility Name: *Towne Place Suites*
Address: *2020 Cool Springs Dr.*
Cranberry Township, PA 16066

Sample Collection

Date: *7/9/25*
Time: *1:24 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *7/12/25*
Time: *8:30 AM*
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/10/25	10:50 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/10/25	10:50 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/9/25	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/9/25	1:24 PM	ZR	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/9/25	1:24 PM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/9/25	1:24 PM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor