



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 269**

**Customer**

**Facility Name:** Science and Technology Academy

**Address:** 107 Thackeray St.  
Pittsburgh, PA 15213

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Collection**

**Date:** 2/2/26

**Time:** 9:18 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 2/5/26

**Time:** 10:30 AM

**Analyst:** AS

Accredited Analysis	Results	Rating	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	2/3/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	2/3/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	2/2/26	4:10 PM	SL	SM 9215B

Field Analysis	Results	Rating		Date/Time	Analyst	Method
pH:	7.4 SU	A	2/2/26	9:18 AM	MM	DPD
Chlorine:	2.5 mg/l	B	2/2/26	9:18 AM	MM	DPD
Turbidity:	1 NTU	A	2/2/26	9:18 AM	MM	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)