Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# *2131*

Customer

Facility Name:	*Cork Factory*
Address:	*2349 Rail Road St.*
	Pittsburgh, PA 15222
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*6/24/25*
Time:	9:00 AM
Method:	*Grab*

Sample Final Analysis

Date:	*6/27/25*
Time:	*9:20 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	10:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	9:00 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	9:00 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	9:00 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# *2131*

Customer

Facility Name:	*Cork Factory*		
Address:	*2349 Rail Road St.* *Pittsburgh, PA 15222*		
Matrix:	*Recreational Water*		
Source Type:	*Pool*		

Sample Collection

Date:	*6/24/25*
Time:	9:00 AM
Method:	*Grab*

Sample Final Analysis

Date:	*6/27/25*
Time:	*9:20 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	10:50 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	10:50 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/24/25	5:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/24/25	9:00 AM	LM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/24/25	9:00 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/24/25	9:00 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor