Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab#   251

Customer		**Sample Collection**	
Facility Name:	*Penn Trafford H.S.*	*Date:*	*7/1/25*
		Time:	11:50 AM
Address:	*3381 Route 130*	*Method:*	*Grab*
	Harrison City, PA 15636		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*7/4/25*
		Time:	*9:30 AM*
Source Type:	*Pool*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	7/2/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	4:00 PM	EB	SM 9215B

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	11:50 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	11:50 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	11:50 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer		_Sample Collection_	
Facility Name:	Penn Trafford H.S.	Date:	7/1/25
		Time:	11:50 AM
Address:	3381 Route 130	Method:	Grab
	Harrison City, PA 15636		
		Sample Final Analysis	
Matrix:	Recreational Water	Date:	7/4/25
		Time:	9:30 AM
Source Type:	Pool	Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	4:00 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/1/25	11:50 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/1/25	11:50 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	11:50 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor