



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2723

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Traditions of America Southpointe
Address: 105 Liberty Blvd.
Cannonsburg, PA 15317

Date: 8/19/25
Time: 12:17 PM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Pool

Date: 8/22/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/20/25 11:15 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/20/25 11:15 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/19/25 5:20 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|-----------|-----------------|------------------|---------|--------|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 8/19/25 12:17 PM | AF | DPD |
| Chlorine: | 10.0 mg/l | 1.0 - 5.0 mg/l | 8/19/25 12:17 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/19/25 12:17 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor