



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-2**

**Lab# 347**

**Customer**

**Facility Name:** Wyndham Grand  
**Address:** 600 Commonwealth Place  
Pittsburgh, PA 15222

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 1/27/26  
**Time:** 12:55 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 1/30/26  
**Time:** 11:00 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/28/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/28/26	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/27/26	5:16 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	1/27/26	12:55 PM	BH	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	1/27/26	12:55 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/27/26	12:55 PM	BH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor