



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 013

Customer

Facility Name: *Bairel Center*
Address: *2565 Nicholson Rd.*
Sewickley, PA 15143

Sample Collection

Date: *12/3/25*
Time: *10:30 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool Deep*

Sample Final Analysis

Date: *12/5/25*
Time: *3:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/3/25	3:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/3/25	3:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/3/25	3:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	12/3/25	10:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/3/25	10:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/3/25	10:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor