

## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-12

Lab# 038

Customer

Carlynton H.S.

Facility Name:

435 Kings Highway Address:

Carnegie, PA 15106

Matrix: Recreational Water

Source Type: Deep End Sample Collection

Date: Time:

5/28/25 10:00 AM

Method: Grab

Sample Final Analysis

Date: Time:

5/31/25 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Da	te/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:25 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	10:00 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	10:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	10:00 AM	VH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith



## 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

W-12

Lab# 038

Customer

Carlynton H.S.

Facility Name:

435 Kings Highway Address:

Carnegie, PA 15106

Matrix: Recreational Water

Source Type: Deep End Sample Collection

Date: Time:

5/28/25 10:00 AM

Method: Grab

Sample Final Analysis

Date: Time:

5/31/25 9:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Da	te/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/29/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/29/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/28/25	3:25 PM	АН	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/28/25	10:00 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/28/25	10:00 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	10:00 AM	VH	Visual

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith