

Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2060

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brightwood Plaza Apts

Address: 4940 Brightwood Plaza

Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 8/6/25

 Time:
 1:50 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 8/8/25

 Time:
 2:00 PM

 Analyst:
 AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 8/6/25 4:50 PM AS SM 9222G Total coliforms: 0/100mls AS 2/100mls 8/6/25 4:50 PM SM 9222B Standard plate count: 0/ml 200/ml 8/6/25 3:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	8/6/25	1:50 PM	CW	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/6/25	1:50 PM	CW	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	1:50 PM	CW	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2060

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brightwood Plaza Apts

Address: 4940 Brightwood Plaza

Bethel Park, PA 15102

Matrix: Recreational Water

Source Type: Pool

Sample Collection

 Date:
 8/6/25

 Time:
 1:50 PM

 Method:
 Grab

Sample Final Analysis

 Date:
 8/8/25

 Time:
 2:00 PM

 Analyst:
 AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 8/6/25 4:50 PM AS SM 9222G Total coliforms: 0/100mls AS 2/100mls 8/6/25 4:50 PM SM 9222B Standard plate count: 0/ml 200/ml 8/6/25 3:40 PM AS SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method	
pH:	7.2 SU	7.2 - 7.8 SU	8/6/25	1:50 PM	CW	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/6/25	1:50 PM	CW	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/6/25	1:50 PM	CW	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor