

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 SERVICE

Lab# 2509

Customer Sample Collection

Facility Name: Staunton Date: 6/30/25
Time: 9:20 AM

Address: 1501 Staunton Drive Method: Grab
Moon Township, PA 15108

Matrix: Recreational Water Sample Final Analysis

Date: 7/3/25

Source Type: Pool Time: 9:30 AM
Analyst: AS

**Reporting limit Accredited Analysis** Results **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 7/1/25 11:30 AM AHSM 9222G Total coliforms: 0/100mls 2/100mls 7/1/25 11:30 AM AΗ SM 9222B SL Standard plate count: 200/ml 6:00 PM SM 9215B 0/ml 6/30/25

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.2 SU   | 7.2 - 7.8 SU    | 6/30/25   | 9:20 AM | АН      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 6/30/25   | 9:20 AM | АН      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/30/25   | 9:20 AM | АН      | Visual |

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 SERVICE

Lab# 2509

Customer Sample Collection

Facility Name: Staunton Date: 6/30/25
Time: 9:20 AM

Address: 1501 Staunton Drive Method: Grab
Moon Township, PA 15108

Matrix: Recreational Water Sample Final Analysis

Date: 7/3/25

Source Type: Pool Time: 9:30 AM
Analyst: AS

**Reporting limit Accredited Analysis** Results **Analyst** Method **Incubation Date/Time** Escherichia Coli: Absent Absent 7/1/25 11:30 AM AHSM 9222G Total coliforms: 0/100mls 2/100mls 7/1/25 11:30 AM AΗ SM 9222B SL Standard plate count: 200/ml 6:00 PM SM 9215B 0/ml 6/30/25

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.2 SU   | 7.2 - 7.8 SU    | 6/30/25   | 9:20 AM | АН      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 6/30/25   | 9:20 AM | АН      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/30/25   | 9:20 AM | АН      | Visual |

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor