



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2228

Customer

Facility Name: Glennwood Condo
Address: 430 Cannongate Drive
Monroeville, PA 15146

Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/19/25
Time: 1:58 PM
Method: Grab

Sample Final Analysis

Date: 8/22/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/20/25	10:05 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/20/25	10:05 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/19/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/19/25	1:58 PM	EH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/19/25	1:58 PM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/19/25	1:58 PM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor