



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2506

Customer

Facility Name: St Clair Country Club
Address: 2300 Old Washington Rd.
Pittsburgh, PA 15241

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 6/16/25
Time: 3:19 PM
Method: Grab

Sample Final Analysis

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/16/25	3:19 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/16/25	3:19 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	3:19 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2506

Customer

Facility Name: St Clair Country Club
Address: 2300 Old Washington Rd.
Pittsburgh, PA 15241

Matrix: Recreational Water

Source Type: Baby Pool

Sample Collection

Date: 6/16/25
Time: 3:19 PM
Method: Grab

Sample Final Analysis

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	11:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	11:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/16/25	3:19 PM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/16/25	3:19 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	3:19 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Anaë Smith