



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 360

Customer

Facility Name: YMCA - Mon-Valley
Address: 101 Taylor Run Road
Monongahela, PA 15063

Sample Collection

Date: 11/17/25
Time: 2:25 PM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 11/20/25
Time: 10:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|---------------------|---------|-----------------|------------|-----------|---------|--------|
|---------------------|---------|-----------------|------------|-----------|---------|--------|

| | | | | | | |
|-----------------------|----------|----------|----------|----------|----|----------|
| Escherichia Coli: | Absent | Absent | 11/18/25 | 10:30 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 11/18/25 | 10:30 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 11/17/25 | 5:08 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation | Date/Time | Analyst | Method |
|---------------------|---------|-----------------|------------|-----------|---------|--------|
|---------------------|---------|-----------------|------------|-----------|---------|--------|

| | | | | | | |
|---------------------|----------|----------|----------|----------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 11/18/25 | 11:30 AM | SL | SM 9230C |
|---------------------|----------|----------|----------|----------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

| | | | | | | |
|------------|----------|----------------|----------|---------|----|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 11/17/25 | 2:25 PM | SH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 11/17/25 | 2:25 PM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 11/17/25 | 2:25 PM | SH | Visual |

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)