Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 372

Customer

			Sample Collection	
Facility Name:	Pine Richland H.S.		*Date:*	7/2/25
			Time:	12:25 PM
Address:	700 Warrendale Rd.		*Method:*	Grab
	Gibsonia, PA 15044			
			Sample Final Analysis	
Matrix:	Recreational Water		*Date:*	7/4/25
			Time:	3:30 PM
Source Type:	Deep End		*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/2/25	12:25 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/2/25	12:25 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	12:25 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 372

Customer

Facility Name:	Pine Richland H.S.
Address:	700 Warrendale Rd.
	Gibsonia, PA 15044
Matrix:	Recreational Water
Source Type:	Deep End

Sample Collection

Date:	7/2/25
Time:	12:25 PM
Method:	Grab

Sample Final Analysis

Date:	7/4/25
Time:	3:30 PM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	6:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	6:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/2/25	5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/2/25	12:25 PM	CW	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	7/2/25	12:25 PM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/2/25	12:25 PM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor