



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206 **PPS**
(412) 661-7665
Laboratory Analysis Report Lab# 019

Lab ID No. 02-04041

<u>Customer</u>		<u>Sample Collection</u>			
Facility Name:	Baxter Building	Date:	11/12/25		
Address:	925 Brushton Ave Pittsburgh, PA 15208	Time:	10:51 AM		
Matrix:		<u>Sample Final Analysis</u>			
Source Type:	Recreational Water	Date:	11/14/25		
	Pool Shallow	Time:	5:00 PM		
		Analyst:	AS		
Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	A	11/12/25 4:45 PM	SL	SM 9222G
Total coliforms:	0/100mls	A	11/12/25 4:45 PM	SL	SM 9222B
Standard plate count:	0/ml	A	11/12/25 4:45 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time	Analyst	Method
pH:	7.4 SU	A	11/12/25 10:51 AM	MM	DPD
Chlorine:	2.0 mg/l	B	11/12/25 10:51 AM	MM	DPD
Turbidity:	1 NTU	A	11/12/25 10:51 AM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)