



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2153

Customer

Facility Name: *Dominion Homeowners*

Address: *1484 Zenith Court*
Pittsburgh, PA 15241

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/4/25*

Time: *11:32 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/7/25*

Time: *11:20 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	11:32 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:32 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:32 AM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2153

Customer

Facility Name: *Dominion Homeowners*

Address: *1484 Zenith Court*
Pittsburgh, PA 15241

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/4/25*

Time: *11:32 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/7/25*

Time: *11:20 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/25	10:50 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/25	10:50 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/25	4:55 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/25	11:32 AM	AF	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/25	11:32 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/25	11:32 AM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor