



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 405

Customer

Facility Name: Home 2 Suites Beaver Valley
Address: 1000 Wagner Road Extension South
Monaca, PA 15061

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 2/2/26
Time: 1:31 PM
Method: Grab

Sample Final Analysis

Date: 2/5/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/3/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/3/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	2/2/26	5:03 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	2/2/26	1:31 PM	AMH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	2/2/26	1:31 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/2/26	1:31 PM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)