



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 062

Customer

Facility Name: *Comfort Inn - Butler*

Address: *1 Comfort Lane
Butler, PA 16001*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/9/25*

Time: *11:35 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/12/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	10:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:40 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/9/25	11:35 AM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/9/25	11:35 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	11:35 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 062

Customer

Facility Name: *Comfort Inn - Butler*

Address: *1 Comfort Lane*
Butler, PA 16001

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/9/25*

Time: *11:35 AM*

Method: *Grab*

Sample Final Analysis

Date: *6/12/25*

Time: *9:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	10:35 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	10:35 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/25	5:40 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/9/25	11:35 AM	BH	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	6/9/25	11:35 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	11:35 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor