



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 321

Customer

Facility Name: *Upper St. Clair Rec.*
Address: *1551 Mayview Rd.*
Pittsburgh, PA 15241

Sample Collection

Date: *8/11/25*
Time: *3:28 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *8/14/25*
Time: *9:00 AM*
Analyst: *AS*

Source Type: *Leasure Shallow End*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/12/25 | 10:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/12/25 | 10:30 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/11/25 | 5:20 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 8/11/25 | 3:28 PM | AF | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 8/11/25 | 3:28 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/11/25 | 3:28 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 321

Customer

Facility Name: Upper St. Clair Rec.
Address: 1551 Mayview Rd.
Pittsburgh, PA 15241

Sample Collection

Date: 8/11/25
Time: 3:28 PM
Method: Grab

Matrix: Recreational Water

Source Type: Leasure Shallow End

Sample Final Analysis

Date: 8/14/25
Time: 9:00 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 8/12/25 | 10:30 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 8/12/25 | 10:30 AM | AH | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 8/11/25 | 5:20 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 8/11/25 | 3:28 PM | AF | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 8/11/25 | 3:28 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/11/25 | 3:28 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor