



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 073

Customer

Facility Name: Courtyard by Marriott
Address: 401 West Waterfront Dr.
West Homestead, PA 15120

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 12/29/25
Time: 7:50 AM
Method: Grab

Sample Final Analysis

Date: 1/1/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	12/30/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/30/25	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	12/29/25	5:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	12/29/25	7:50 AM	SH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	12/29/25	7:50 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/29/25	7:50 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor