



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 2748**

**Customer**

**Facility Name:** Seven Oaks C.C.  
  
**Address:** 132 Lisbon Road  
Beaver, PA 15009  
  
**Matrix:** Recreational Water  
  
**Source Type:** Shallow End

**Sample Collection**

**Date:** 6/4/25  
**Time:** 2:00 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/6/25  
**Time:** 4:00 PM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/4/25	2:00 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/4/25	2:00 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	2:00 PM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-10**

**Lab# 2748**

**Customer**

Facility Name: Seven Oaks C.C.

Address: 132 Lisbon Road  
Beaver, PA 15009

Matrix: Recreational Water

Source Type: Shallow End

**Sample Collection**

Date: 6/4/25

Time: 2:00 PM

Method: Grab

**Sample Final Analysis**

Date: 6/6/25

Time: 4:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/4/25	2:00 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/4/25	2:00 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	2:00 PM	SL	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor