



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206 **PPS**
(412) 661- 7665
Laboratory Analysis Report Lab# 019

Lab ID No. 02-04041

<u>Customer</u>		<u>Sample Collection</u>		<u>Sample Final Analysis</u>		
Facility Name:	Baxter Building	Date:	1/5/26	Date:	1/8/26	
Address:	925 Brushton Ave Pittsburgh, PA 15208	Time:	9:55 AM	Time:	9:30 AM	
Matrix:	Recreational Water	Method:	Grab	Analyst:	AS	
Source Type:	Pool Shallow					
Accredited Analysis	Results	Rating	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	A	1/6/26	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	1/6/26	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	1/5/26	5:00 PM	SL	SM 9215B
Field Analysis	Results	Rating	Date/Time	Analyst	Method	
pH:	7.4 SU	A	1/5/26	9:55 AM	MM	DPD
Chlorine:	1.0 mg/l	D	1/5/26	9:55 AM	MM	DPD
Turbidity:	1 NTU	A	1/5/26	9:55 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)