



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2157

Customer

Facility Name: Doubletree Hotel
Address: 340 Racetrack Road
Washington, PA 15301
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/12/25
Time: 11:17 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	9:30 AM	EB
Total coliforms:	0/100mls	2/100mls	8/13/25	9:30 AM	EB
Standard plate count:	5700/ml	200/ml	8/12/25	2:56 PM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	11:17 AM	GR
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/12/25	11:17 AM	GR
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	11:17 AM	GR

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 2157

Customer

Facility Name: Doubletree Hotel
Address: 340 Racetrack Road
Washington, PA 15301
Matrix: Recreational Water
Source Type: Pool

Sample Collection

Date: 8/12/25
Time: 11:17 AM
Method: Grab

Sample Final Analysis

Date: 8/15/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/25	9:30 AM	EB
Total coliforms:	0/100mls	2/100mls	8/13/25	9:30 AM	EB
Standard plate count:	5700/ml	200/ml	8/12/25	2:56 PM	AH

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/25	11:17 AM	GR
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/12/25	11:17 AM	GR
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	11:17 AM	GR

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor