



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

E-3

Lab# 475

<u>Customer</u>		<u>Sample Collection</u>			
Facility Name:	Altoona HS	Date:	2/17/26		
Address:	1404 6th Ave Altoona, PA 16602	Time:	2:30 PM		
Matrix:		<u>Method:</u> Grab			
Source Type:	Pool	Date:	2/19/26		
Source Type:	Pool	Time:	10:30 AM		
Source Type:	Pool	Analyst:	AS		
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method

Escherichia Coli:	Absent	Absent	2/18/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/18/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/17/26	5:25 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	2/17/26	2:30 PM	DNP	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	2/17/26	2:30 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/17/26	2:30 PM	DNP	Visual

Sample comments

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor