Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

B & R Pools and Swim Shop

Customer			*Sample Collection*	
Facility Name:	*Norberry*		*Date:*	7/14/25
			Time:	10:52 AM
Address:	*Norberry Ct.*		*Method:*	*Grab*
	Cranberry, PA 16066			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/17/25*
			Time:	*8:30 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:53 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/14/25	10:52 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:52 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:52 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer			*Sample Collection*	
Facility Name:	Norberry		*Date:*	7/14/25
			Time:	10:52 AM
Address:	Norberry Ct.		*Method:*	Grab
	Cranberry, PA 16066			
			Sample Final Analysis	
Matrix:	Recreational Water		*Date:*	7/17/25
			Time:	8:30 AM
Source Type:	Pool		*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/15/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/15/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/14/25	3:53 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/14/25	10:52 AM	ZR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/14/25	10:52 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/14/25	10:52 AM	ZR	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)