

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 C-11

Lab# 032

Customer

Facility Name: Cambria Suites

Address: 1320 Centre Ave

Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/29/25 Time: 10:30 AM

Method: Grab

Sample Final Analysis

Date: 8/1/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	ЕВ	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/30/25	10:50 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/29/25	10:30 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/29/25	10:30 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	10:30 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 C-11

Lab# 032

Customer

Facility Name: Cambria Suites

Address: 1320 Centre Ave

Pittsburgh, PA 15219

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 7/29/25 Time: 10:30 AM

Method: Grab

Sample Final Analysis

Date: 8/1/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	10:00 AM	ЕВ	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/29/25	4:00 PM	АН	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	7/30/25	10:50 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	7/29/25	10:30 AM	LM	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/29/25	10:30 AM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/29/25	10:30 AM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith, Lead Supervisor