



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665

Lab ID No. 02-04041

W-2

Lab# 414

Laboratory Analysis Report

<u>Customer</u>		<u>Sample Collection</u>				
Facility Name:	Town Place Airport	Date:	2/10/26			
Address:	1006 Sutherland Dr. Pittsburgh, PA 15205	Time:	12:15 PM		Method: Grab	
<u>Sample Final Analysis</u>						
Matrix:	Recreational Water	Date:	2/13/26			
Source Type:	Spa	Time:	10:30 AM		Analyst: AS	
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	2/11/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/11/26	10:00 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	2/10/26	3:20 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Fecal Streptococcus	0/100mls	2/100mls	2/11/26	10:20 AM	SL	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	2/10/26	12:15 PM	VH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	2/10/26	12:15 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/10/26	12:15 PM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)