



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 2727**

**Customer**

Facility Name: *Montour CC*  
  
Address: *1491 Coraopolis Heights Rd*  
*Coraopolis, PA 15108*

Matrix: *Recreational Water*

Source Type: *Deep End*

**Sample Collection**

Date: *8/5/25*  
Time: *12:00 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *8/8/25*  
Time: *8:30 AM*  
Analyst: *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/6/25               | 9:20 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/6/25               | 9:20 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/5/25               | 4:00 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 8/5/25    | 12:00 PM | VH      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 8/5/25    | 12:00 PM | VH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/5/25    | 12:00 PM | VH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anaë Smith*



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-11**

**Lab# 2727**

**Customer**

Facility Name: *Montour CC*  
  
Address: *1491 Coraopolis Heights Rd*  
*Coraopolis, PA 15108*

Matrix: *Recreational Water*

Source Type: *Deep End*

**Sample Collection**

Date: *8/5/25*  
Time: *12:00 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *8/8/25*  
Time: *8:30 AM*  
Analyst: *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/6/25               | 9:20 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/6/25               | 9:20 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/5/25               | 4:00 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 8/5/25    | 12:00 PM | VH      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 8/5/25    | 12:00 PM | VH      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/5/25    | 12:00 PM | VH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Anaë Smith*