



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 003

Customer

Facility Name: *Allderdice H.S.*
Address: *2409 Shady Ave.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *1/5/26*
Time: *10:36 AM*
Method: *Grab*

Sample Final Analysis

Date: *1/8/26*
Time: *9:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	1/6/26	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	1/6/26	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	1/5/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	1/5/26	10:36 AM	MM	DPD
Chlorine:	3.0 mg/l	A	1/5/26	10:36 AM	MM	DPD
Turbidity:	1 NTU	A	1/5/26	10:36 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor