



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-14

Lab# 477

Customer

Facility Name: Comfort Inn Duncansville
Address: 130 Patchway Rd.
Duncansville, PA 16635

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/27/25
Time: 12:40 PM
Method: Grab

Sample Final Analysis

Date: 5/30/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25 10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25 10:15 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	5/27/25 5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/27/25 12:40 PM	DP	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/27/25 12:40 PM	DP	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25 12:40 PM	DP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-14

Lab# 477

Customer

Facility Name: *Comfort Inn Duncansville*
Address: *130 Patchway Rd.*
Duncansville, PA 16635

Sample Collection

Date: *5/27/25*
Time: *12:40 PM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *5/30/25*
Time: *9:00 AM*
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/28/25 10:15 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/28/25 10:15 AM	EB	SM 9222B
Standard plate count:	200/ml	200/ml	5/27/25 5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/27/25 12:40 PM	DP	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/27/25 12:40 PM	DP	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/27/25 12:40 PM	DP	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor