

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2015

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Allegheny C.C. Date: 6/18/25

Address: 250 Country Club Rd Time: 12:15 PM Method: Grab

Sewickley, PA 15143

Matrix: Recreational Water Sample Final Analysis

Date: 6/20/25

Source Type: Baby Pool Time: 3:30 PM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent 6/18/25 4:05 PM EΒ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 6/18/25 4:05 PM EΒ SM 9222B Standard plate count: 0/ml 200/ml 6/18/25 4:05 PM EΒ SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/18/25 | 12:15 PM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/18/25 | 12:15 PM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/18/25 | 12:15 PM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2015

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Allegheny C.C. Date: 6/18/25

Address: 250 Country Club Rd Time: 12:15 PM Method: Grab

Sewickley, PA 15143

Matrix: Recreational Water Sample Final Analysis

Date: 6/20/25

Source Type: Baby Pool Time: 3:30 PM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method Escherichia Coli: Absent 6/18/25 4:05 PM EΒ SM 9222G Absent Total coliforms: 0/100mls 2/100mls 6/18/25 4:05 PM EΒ SM 9222B Standard plate count: 0/ml 200/ml 6/18/25 4:05 PM EΒ SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 6/18/25 | 12:15 PM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 6/18/25 | 12:15 PM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/18/25 | 12:15 PM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor