



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-16**

**Lab# 2340**

**Customer**

**Facility Name:** *McCandless Swim Club*  
**Address:** *Red coach & Thompson Run Rd.*  
*McCandless, PA 15237*

**Sample Collection**

**Date:** *6/23/25*  
**Time:** *9:31 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Deep End*

**Sample Final Analysis**

**Date:** *6/26/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	4:02 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	9:31 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/25	9:31 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	9:31 AM	GR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-16**

**Lab# 2340**

**Customer**

**Facility Name:** *McCandless Swim Club*  
**Address:** *Red coach & Thompson Run Rd.*  
*McCandless, PA 15237*

**Sample Collection**

**Date:** *6/23/25*  
**Time:** *9:31 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*  
**Source Type:** *Deep End*

**Sample Final Analysis**

**Date:** *6/26/25*  
**Time:** *9:00 AM*  
**Analyst:** *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/24/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/24/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/23/25	4:02 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/23/25	9:31 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/23/25	9:31 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/23/25	9:31 AM	GR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

*Andre Smith*

Andre Smith, Lead Supervisor