



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2010

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Adams Ridge	<b><u>Sample Collection</u></b>				
Address:	100 Adams Ridge Blvd. Mars, PA 16046	Date:	8/12/25			
Matrix:	Recreational Water	Time:	10:42 AM			
Source Type:	Baby Pool	Method:	Grab			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/13/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	5:35 PM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.1 SU	7.2 - 7.8 SU	8/12/25	10:42 AM	ZS	DPD
Chlorine:	6.0 mg/l	1.0 - 5.0 mg/l	8/12/25	10:42 AM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:42 AM	ZS	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

APM 1

Lab# 2010

**Customer** American Pools Management  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

Facility Name:	Adams Ridge	<b><u>Sample Collection</u></b>				
Address:	100 Adams Ridge Blvd. Mars, PA 16046	Date:	8/12/25			
Matrix:	Recreational Water	Time:	10:42 AM			
Source Type:	Baby Pool	Method:	Grab			
Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	8/13/25	11:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/25	11:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/25	5:35 PM	0	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.1 SU	7.2 - 7.8 SU	8/12/25	10:42 AM	ZS	DPD
Chlorine:	6.0 mg/l	1.0 - 5.0 mg/l	8/12/25	10:42 AM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/25	10:42 AM	ZS	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor