

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041
SERVICE

Lab# 121

Customer Sample Collection

Facility Name: Hampton Inn Date: 7/22/25

Address: 301 West Waterfront Dr. Time: 9:30 AM

Method: Grab

Pittsburgh, PA 15120

Matrix: Hampton Inn Sample Final Analysis

Date: 7/25/25

Source Type: Pool Time: 10:00 AM
Analyst: AS

Accredited Analysis Reporting limit Results Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 7/23/25 12:00 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/23/25 12:00 PM AΗ SM 9222B Standard plate count: 0/ml 200/ml 7/22/25 6:00 PM SL SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 7/22/25 | 9:30 AM | DS | DPD |
| Chlorine: | 0.2 mg/l | 1.0 - 5.0 mg/l | 7/22/25 | 9:30 AM | DS | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/22/25 | 9:30 AM | DS | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041
SERVICE

Lab# 121

Customer Sample Collection

Facility Name: Hampton Inn Date: 7/22/25

Address: 301 West Waterfront Dr. Time: 9:30 AM

Method: Grab

Pittsburgh, PA 15120

Matrix: Hampton Inn Sample Final Analysis

Date: 7/25/25

Source Type: Pool Time: 10:00 AM
Analyst: AS

Accredited Analysis Reporting limit Results Incubation Date/Time **Analyst** Method Escherichia Coli: Absent Absent 7/23/25 12:00 PM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 7/23/25 12:00 PM AΗ SM 9222B Standard plate count: 0/ml 200/ml 7/22/25 6:00 PM SL SM 9215B

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 7/22/25 | 9:30 AM | DS | DPD |
| Chlorine: | 0.2 mg/l | 1.0 - 5.0 mg/l | 7/22/25 | 9:30 AM | DS | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/22/25 | 9:30 AM | DS | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor