



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 160**

**Customer**

**Facility Name:** *Holiday Inn Express*

**Address:** *810 Highland Meadow Dr.  
Washington, PA 15301*

**Matrix:** *Recreational Water*

**Source Type:** *Spa*

**Sample Collection**

**Date:** *1/14/26*

**Time:** *12:45 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *1/16/26*

**Time:** *5:30 PM*

**Analyst:** *AS*

<b>Accredited Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	1/14/26	5:18 PM	SL	SM 9222G
-------------------	--------	--------	---------	---------	----	----------

Total coliforms:	0/100mls	2/100mls	1/14/26	5:18 PM	SL	SM 9222B
------------------	----------	----------	---------	---------	----	----------

Standard plate count:	0/ml	200/ml	1/14/26	5:18 PM	SL	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

<b>Additional Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Incubation Date/Time</b>	<b>Analyst</b>	<b>Method</b>
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Fecal Streptococcus	0/100mls	2/100mls	1/14/26	Total coliforms:	SL	SM 9230C
---------------------	----------	----------	---------	------------------	----	----------

<b>Field Analysis</b>	<b>Results</b>	<b>Reporting limit</b>	<b>Date/Time</b>	<b>Analyst</b>	<b>Method</b>
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.4 SU	7.2 - 7.8 SU	1/14/26	12:45 PM	BH	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/14/26	12:45 PM	BH	DPD
-----------	----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	1/14/26	12:45 PM	BH	Visual
------------	-------	-----------	---------	----------	----	--------

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)