



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 203

Customer

Facility Name: L.A. Fitness Greensburg

Address: 3000 Lincoln Place
Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 11/24/25

Time: 1:31 PM

Method: Grab

Sample Final Analysis

Date: 11/27/25

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	11/25/25 10:30 AM	AS	SM 9222G
-------------------	--------	--------	-------------------	----	----------

Total coliforms:	0/100mls	2/100mls	11/25/25 10:30 AM	AS	SM 9222B
------------------	----------	----------	-------------------	----	----------

Standard plate count:	0/ml	200/ml	11/24/25 4:45 PM	AS	SM 9215B
-----------------------	------	--------	------------------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	11/25/25 12:40 PM	AS	SM 9230C
---------------------	----------	----------	-------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.0 SU	7.2 - 7.8 SU	11/24/25 1:31 PM	JC	DPD
-----	--------	--------------	------------------	----	-----

Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/24/25 1:31 PM	JC	DPD
-----------	----------	----------------	------------------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	11/24/25 1:31 PM	JC	Visual
------------	-------	-----------	------------------	----	--------

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)