



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2732

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 7/8/25
Time: 8:30 AM
Method: Grab

Sample Final Analysis

Date: 7/11/25
Time: 9:00 AM
Analyst: AS

Facility Name: Arsenal 201 Phase 2

Address: 3922 Foster St.
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool 2

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|----------------|---------------|
|----------------------------|----------------|------------------------|-----------------------------|----------------|---------------|

| | | | | | |
|-------------------|--------|--------|--------|---------|-------------|
| Escherichia Coli: | Absent | Absent | 7/9/25 | 9:30 AM | EB SM 9222G |
|-------------------|--------|--------|--------|---------|-------------|

| | | | | | |
|------------------|----------|----------|--------|---------|-------------|
| Total coliforms: | 0/100mls | 2/100mls | 7/9/25 | 9:30 AM | EB SM 9222B |
|------------------|----------|----------|--------|---------|-------------|

| | | | | | |
|-----------------------|--------|--------|--------|---------|-------------|
| Standard plate count: | 100/ml | 200/ml | 7/8/25 | 4:30 PM | AH SM 9215B |
|-----------------------|--------|--------|--------|---------|-------------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|-----------------------|----------------|------------------------|------------------|----------------|---------------|
|-----------------------|----------------|------------------------|------------------|----------------|---------------|

| | | | | | |
|-----|--------|--------------|--------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/8/25 | 8:30 AM | LM DPD |
|-----|--------|--------------|--------|---------|--------|

| | | | | | |
|-----------|----------|----------------|--------|---------|--------|
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/8/25 | 8:30 AM | LM DPD |
|-----------|----------|----------------|--------|---------|--------|

| | | | | | |
|------------|-------|-----------|--------|---------|-----------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/8/25 | 8:30 AM | LM Visual |
|------------|-------|-----------|--------|---------|-----------|

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2732

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 7/8/25
Time: 8:30 AM
Method: Grab

Sample Final Analysis

Date: 7/11/25
Time: 9:00 AM
Analyst: AS

Facility Name: Arsenal 201 Phase 2

Address: 3922 Foster St.
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool 2

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|----------------|---------------|
|----------------------------|----------------|------------------------|-----------------------------|----------------|---------------|

| | | | | | | |
|-------------------|--------|--------|--------|---------|----|----------|
| Escherichia Coli: | Absent | Absent | 7/9/25 | 9:30 AM | EB | SM 9222G |
|-------------------|--------|--------|--------|---------|----|----------|

| | | | | | | |
|------------------|----------|----------|--------|---------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 7/9/25 | 9:30 AM | EB | SM 9222B |
|------------------|----------|----------|--------|---------|----|----------|

| | | | | | | |
|-----------------------|--------|--------|--------|---------|----|----------|
| Standard plate count: | 100/ml | 200/ml | 7/8/25 | 4:30 PM | AH | SM 9215B |
|-----------------------|--------|--------|--------|---------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|-----------------------|----------------|------------------------|------------------|----------------|---------------|
|-----------------------|----------------|------------------------|------------------|----------------|---------------|

| | | | | | | |
|-----|--------|--------------|--------|---------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 7/8/25 | 8:30 AM | LM | DPD |
|-----|--------|--------------|--------|---------|----|-----|

| | | | | | | |
|-----------|----------|----------------|--------|---------|----|-----|
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 7/8/25 | 8:30 AM | LM | DPD |
|-----------|----------|----------------|--------|---------|----|-----|

| | | | | | | |
|------------|-------|-----------|--------|---------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/8/25 | 8:30 AM | LM | Visual |
|------------|-------|-----------|--------|---------|----|--------|

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor