Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2161

Customer			*Sample Collection*	
Facility Name:	*Eagle Trace*		*Date:*	*7/22/25*
			Time:	10:55 AM
Address:	*300 Allandale Dr.*		*Method:*	*Grab*
	Bethel Park, PA 15102			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/25/25*
			Time:	*10:00 AM*
Source Type:	*Pool*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	10:55 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:55 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:55 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 2161

Customer
Facility Name: *Eagle Trace*

Address: *300 Allandale Dr.*
Bethel Park, PA 15102

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection
Date: *7/22/25*
Time: 10:55 AM
Method: *Grab*

Sample Final Analysis
Date: *7/25/25*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/23/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/23/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	1/0/00	3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	7/22/25	10:55 AM	CW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	7/22/25	10:55 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/22/25	10:55 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor